



FIGHTNER Consulting Engineers (India) Private Limited, (FI) Chennai.

VENDOR DRAWING REVIEW STATUS

- ☐ Action - 1 Approved
- ☐ Action - 2 Approved except as noted on drawing. Revise drawing and resubmit for records.
- ☐ Action - 3 Returned with Comments. Resubmit for approval.
- ☐ Action - 4 Not Approved. Resubmit for review
- ☒ Information noted. Retained for reference and records.

This document has been reviewed as noted with regard to general conformity with the Contract specifications and requirements. The Vendor/Contractor is responsible for correctness of design calculation and details. Approval of this document does not relieve the Vendor/Contractor of his responsibility in carrying out the work correctly and fulfilling the complete requirements of the contract nor does it limit the purchaser's rights under the contract

FI Letter Ref. No. **CNT 6725/PM-6.7/2390/400**

Signature: *[Signature]*

Date: **17/09/09**

Initials: **TAI**

CC GENERATOR OUTPUT = 363.300 MW

ONGC TRIPURA POWER COMPANY PRIVATE LIMITED	
7666 MW GAS BASED COMBINED CYCLE POWER PLANT, TRIPURA	
BHARAT HEAVY ELECTRICALS LTD	
PROJECT ENGINEERING MANAGEMENT	
NEW DELHI	
PREP	100% CC LOAD, 27°C AMB TEMP, 32°C CV TEMP, 0% MU
CHKD	77% RH, NG FIRING, NDX = 50 ppmvd @ 15% O2
APPD	JOB NO 319
DATE	25/11/08
DRG NO	PE - DC - 319 - 100 - D101
REV	00

RT	KCAL/KG
T/H	°C (X)
M..MASS FLOW..T/H	
H..ENTHALPY..KCAL/KG	
T..TEMPERATURE..°C	

FOR INFORMATION ONLY