



KEYPLAN:

BILL OF MATERIALS:-

S.No.	SYMBOL	TYPE	DESCRIPTION	QNTY.
01	⊗	SW1	70W HPSV AC NORMAL WELL GLASS LUMINAIRE (CGL - SWV1207/EQUIVALENT)	02 Nos.
02	-	-	3Cx4 Sq.mm. Cu. ARMoured CABLE	45M
03	-	-	40NB 'B' CLASS PIPE	02 Nos.
04	-	-	150WX200HX6 THK. GALVANISED M.S.PLATE	02 Nos.
05	-	-	8MM DIA. 'U' BOLT	04 Nos.

NOTES:

01. ALL DIMENSIONS ARE IN MILLIMETRES AND LEVELS ARE IN METRES.
02. CABLE ROUTING SHOWN IS ONLY INDICATIVE. THE ACTUAL CABLE ROUTING SHALL BE DONE AS PER SITE CONDITION.
03. LP AND FIXTURE CIRCUIT NUMBERING SHALL BE READ AS FOLLOWS

REFERENCE DRAWINGS:-

01. PE-DG-319-100-M001 - PLOT PLAN

R0	27.12.13	FOR APPROVAL	KR			DJS	
REV.	DATE	DESCRIPTION	DRN.	STR.	MECH.	ELEC.	INST.
							APPROVED BY
FICHTNER Consulting Engineers (India) Private Limited Chennai			ONGC TRIPURA POWER COMPANY PRIVATE LIMITED. 726.6 MW COMBINED CYCLE POWER PROJECT PALLATANA, TRIPURA				
DRAWN	KR	27.12.13	TITLE STORM WATER PIT -1 LIGHTING LAYOUT				
DESIGNED	RSV	27.12.13					
CHECKED	RSV	27.12.13					
DEPT. HEAD	DJS	27.12.13					
PROJ. MGR.	DKS/RUV	27.12.13					
RELEASED FOR	PRELIMINARY		DEPT. ELECT.	JOB NO.	1113112	SCALE:	1:125
	TENDER	✓	DWG. NO.	30-1113112-E-002			REV.
	ENGINEERING						R0